


Door Strike Connection Diagram



Important: If the device is used as an Access Control System, an additional Diode connection is required to avoid back EMF from the Door Strike, which could damage the ACTAttek unit.